

Anexo 4 - Datos estaciones de bombeo ACUEDUCTO NORTE -

ACUEDUCTO NORTE													
	PLAN GENERAL (30 años)							1ª ETAPA - Tramo A-					
	Nº BOMBAS	Q30ANOS (l/seg)	H(mam) m	Caudal por Bomba(l/seg)	Potencia por Bomba(kW)	Pot.motor Total (kw)		Nº BOMBAS	Tramo I - Etapa A (l/seg)	H(mam) m	Caudal por Bomba(l/seg)	Potencia por Bomba(kw)	Pot.motor Total (kw)
TOMA	4=(3+1)	2348	40	782.79	415.41	1433.16	TOMA	2=(1+1)	1259	35	1258.95	584.59	672.28
EB1	4=(3+1)	2237	155	745.51	1533.06	5289.04	EB1	2=(1+1)	1199	80	1199.00	1272.57	1463.46
EB2	4=(3+1)	1390	153	463.44	940.72	3245.49	EB2	2=(1+1)	852	65	852.00	734.73	844.94
EB3	4=(3+1)	1380	159	459.98	970.31	2498.18	EB3	2=(1+1)	842	70	842.00	781.96	899.25
EB4	3=(2+1)	236	159	118.14	249.20	573.16							
EB5	3=(2+1)	562	156	281.07	581.72	1337.95							
EB6	3=(2+1)	320	159	159.83	337.14	775.43							
EB7	3=(2+1)	160	147	80.00	156.01	358.82							
EB8	3=(2+1)	94	159	46.92	98.98	227.64							